



THE PORT AUTHORITY OF NY & NJ

**THE PORT AUTHORITY OF NEW YORK & NEW JERSEY
PURCHASING SERVICES DIVISION
ONE MADISON AVENUE 7TH FL.
NEW YORK, NY 10010**

Date 3/2/10

ADDENDUM #1

To prospective bidders/proposers on bid/RFP # 20483 for Electrical Items Per Material List

Due back on 3/9/10, no later than 11:00AM

Originally due on 3/9/10, no later than 11:00AM

The following changes are hereby made in the documents:

QUESTIONS & ANSWERS

The following information is made available in response to questions submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority of NY & NJ has deemed to require additional information and /or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidder does not mean or imply, nor should it be deemed to have any meaning, construction or implication with respect to the terms and provisions of the bid which will be construed without reference to such questions..

Question:

Item # 5 is not a good Crouse Hinds number, but we can quote Nema 4X panelboard. Just need to know , how many secondary breakers you need, poles and amp rating.

Answer:

Item # 5

We require the panel board described to include a 2 pole 80 amp main breaker, 2- 2pole 20's and 18- 1 pole 20's total of 24 ckts, with KED option (key entry door). Panel shall be NEMA 4X rated.

The Part number indicated on original bill of materials is incorrect. Use above description to provide your quotation. INCLUDE THIS ADDENDUM with your bid.

Bid due date & time is unchanged.

PS11All

This communication should be initialed by you and annexed to your bid/proposal upon submission.

In case any bidder/proposer fails to conform to these instructions, its bid/proposal will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

JANE CETERKO, MANAGER
PURCHASING SERVICES DIVISION

BIDDER'S/PROPOSER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO
T. INGENITO, WHO CAN BE REACHED AT (212) 435-3921.