



THE PORT AUTHORITY OF NY & NJ

**THE PORT AUTHORITY OF NEW YORK & NEW JERSEY
PURCHASING SERVICES DIVISION
ONE MADISON AVENUE 7TH FL.
NEW YORK, NY 10010**

Date July 20, 2010

ADDENDUM #1

To prospective bidders/proposers on bid/RFP # 21902 for Pipes and Pipe Fittings

Due back on August 13, 2010, no later than 11:00AM

Originally due on _____, no later than _____

The following changes are hereby made in the documents:

LINE #6 VICTAULIC BRAND 4"X 4"X 3" #29 GALVANIZED is deleted in its entirety and replaced with VICTAULIC BRAND 4" X 4" X 4" #29 GALVANIZED.

QUESTIONS & ANSWERS

The following information is made available in response to questions submitted by Bidders to the Port Authority. It addresses only those questions, which the Port Authority of NY & NJ has deemed to require additional information and /or clarification. The fact that information has not been supplied with respect to any questions asked by a Bidder does not mean or imply, nor should it be deemed to have any meaning, construction or implication with respect to the terms and provisions of the bid which will be construed without reference to such questions.

Question #1

I need more info to finish the quotation. On the expansion joints I need to know: The application (what is going through them), the pressure, the temperature, the movement required on the expansion and the end fitting types of the joints. These were the (2) 4" double bell flex expansion joint epoxy coated, (4) 6" exp joint w/ 2 diff centerline measurements.

PS11A11

Answer #1

The application is water.
The pressure is 350PSI.
The temperature is Ambient Water.
The movement required on the expansion:
Total Axial Compression is 24 inches
Total Axial Extension is 4 inches
The end fitting types of the joints is Flanged.

This communication should be initialed by you and annexed to your bid/proposal upon submission.

In case any bidder/proposer fails to conform to these instructions, its bid/proposal will nevertheless be construed as though this communication had been so physically annexed and initialed.

THE PORT AUTHORITY OF NY & NJ

JANE CETERKO, MANAGER
PURCHASING SERVICES DIVISION

BIDDER'S/PROPOSER'S FIRM NAME: _____

INITIALED: _____

DATE: _____

QUESTIONS CONCERNING THIS ADDENDUM MAY BE ADDRESSED TO
SHANTA NELSON, WHO CAN BE REACHED AT (212) 435-3980.